




Engineering Services
P. O. Box 2570
Waco, TX. 76702-2570
254/750-6620
Fax: 254/750-6641
www.waco-texas.com

**916 South 16th Street Sewer
ADDENDUM #2
January 5th, 2012**

1. The additional 185 linear feet of new 8" sewer that Addendum #1 issues goes against what the Record Drawings in the bid package show. The City's Water Department was unable to go beyond the 185 feet in the sewer line and believe that the sewer main does not run to Ross Avenue.
2. On the Bid Proposal, Bid Item 17 has been changed from "4' Diameter Fiberglass manhole (0'-5' deep) with standard cover" to "4' Diameter manhole (0'-5' deep) with standard cover." Only Page one (1) of the bid proposal is attached to the addendum to reflect this change.

ALL BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE PROPOSAL FORM ON THE SHEET LABELED "BID FOR UNIT PRICE CONTRACT."


George W. Hill, P.E.
Engineering Administrator



Bid Proposal For
916 South 16th St Sewer

Item No.	Description	Est. Qty.	Unit Meas.	Unit Price	Item Amount
1	MOBILIZATION	1	LS	_____	_____
2	EROSION AND SEDIMENT CONTROL MAP (1 ACRE OR LESS)	1	LS	_____	_____
3	EROSION CONTROL IMPLEMENTATION	1	LS	_____	_____
4	CONFINED SPACE PLAN	1	LS	_____	_____
5	CONFINED SPACE PLAN IMPLEMENTATION	1	LS	_____	_____
6	TRAFFIC CONTROL PLAN	1	LS	_____	_____
7	TRAFFIC PLAN IMPLEMENTATION	1	LS	_____	_____
8	TRENCH SAFETY PLANS	1	LS	_____	_____
9	TRENCH SAFETY IMPLEMENTATION	685	LF	_____	_____
10	VIDEO NEWLY BUILT SEWER LINES	685	LF	_____	_____
<u>STREET</u>					
11	CLASS 'A' SURFACE REPLACEMENT	40	LF	_____	_____
12	CLASS 'D' SURFACE REPLACEMENT	645	LF	_____	_____
<u>SEWER</u>					
13	8" SDR-26 PVC ASTM-2241 (0'-10' TRENCH) INCLUDING EXCAVATION AND ALL BACKFILL	685	LF	_____	_____
14	CONNECT 8" SEWER TO EXISTING MANHOLE	2	EA	_____	_____
15	4" (MIN) SANITARY SEWER SERVICE WITH 2-WAY CLEANOUT AND CONNECT TO PRIVATE SERVICE	13	EA	_____	_____
16	4" (MIN) SANITARY SEWER SERVICE WITH 2-WAY CLEANOUT AND NOT CONNECTED TO PRIVATE SERVICE	3	EA	_____	_____
17	4' DIAMETER MANHOLE (0'-5' DEEP) WITH STANDARD COVER	2	EA	_____	_____
18	EXTRA DEPTH FOR 4' DIAMETER MANHOLE OVER 5' DEEP	5	VF	_____	_____
TOTAL AMOUNT OF MATERIALS				_____	_____
TOTAL AMOUNT OF LABOR & EQUIPMENT				_____	_____
AMOUNT OF BID				_____	_____

THIS COMPLETED FORM MUST BE SUBMITTED WITH BID