



Engineering Services
P. O. Box 2570
Waco, TX. 76702-2570
254/750-6620
Fax: 254/750-6641
www.waco-texas.com

**Pascal Court Water and Sewer
ADDENDUM #1
January 4th, 2012**

1. On Sheet 1 and 2 of the plans, between Stations 10+00 and 13+78, the surface replacement class callout is incorrect and should be Class A instead of Class A.1. This will match the Bid Proposal line item #11.
2. On Sheet 6 of the plans, the exact location and depth of the 15" x 24" storm sewer intersection is unknown. It is the responsibility of the contractor to field verify the location and depth.
3. A licensed plumber will be required to do all service work behind the Right of Way line. A no-fee plumbing permit must be obtained for each address at which the licensed plumber will be working.
4. Videoing the new sewer lines shall be done in a manner that includes the linear footage of pipe shown automatically on the video relative to the manhole entered. The manhole in which the camera was inserted shall also be identified as means of reference, along with the direction the camera goes (I.E. upstream or downstream, stationing relative to plans). Additionally, the video format shall be compatible with Windows Media Player and submitted on a DVD. Any other format is unacceptable. The recording shall be conducted in a manner that is slow and allows for visual inspection. The length of the cable connecting to the camera shall be able to reach 250 linear feet, to allow for inspection of every foot of the new main to a maximum of 500 feet between manholes. The camera shall have a mountable, rotating head that can tilt and zoom to identify private services and shall be a motorized unit.
5. All 2" water services shall conform with C.O.W. Standard Detail W-14A. Services not connecting shall include piping up to the curb stop and a meter box, but no meter.
6. On Sheet 2 of the plans, within the profile view, all references to ASTM 3034 shall be changed to read ASTM 2241.
7. The proposed 15' utility easement shown on the plans has already been obtained by the City.
8. Attached is the pre-bid conference sign in sheet and notes.

ALL BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE PROPOSAL FORM ON THE SHEET LABELED "BID FOR UNIT PRICE CONTRACT."

Ann M. Colina, P.E.
Engineering Supervisor



14 DEC '11

Job: _____

Page No.: _____

Subject: _____

Date: _____

Scale: _____

By: _____

PASCAL CRT. PRE-BID

DAVID SALMERI
Quality Construction

254-717-1230

DAVID@Qualityw.com

DONALD BANKS
SUB

OFFICE
836 8100
FAX 836 8102

JOHN HOGAN
COW ENGINEERING

PATRICK RODGERS
C.O.W. ENG.

750-5605
Patrick R@ci.waco.tx.us

Oleyn Morrison
Bear Contractors

826-4441 fax 254/622-3746
oleynmorrison@yahoo.com

NOTES

= CLASS A.1 in 3RD ST (Sheet 1) (Sheet 2)
BE CLASS A needs to

- ADDENDUM to address Storm Drain MH
ON sheet 6

- Licensed Plumber req'd behind R.O.W