

## External Review Comments Received and Comprehensive Responses for Current Draft Standard Details

No.	Standard Detail Alpha-Numeric	COMMENT	BY	DATE	RESPONSE BY 21-MEMBER STANDARD DETAILS MULTI-DEPARTMENTAL INTERDISCIPLINARY TEAM	Means
1	SDW-1, SDW-2, & SDW-4	Have heard comments on the dumpster enclosures. / Via April 28 Developer's Meeting and Email from K. Paul, comment is through and not from K. Paul - The dumpster enclosures are ridiculously large. Most of our projects on existing sites would not be able to accommodate this. The double one is 24 feet clear inside!! The 12'-6" depth is crazy. And don't get me started about the bollard spacing. If the dumpsters are that large, why would you need the bollards that close together?	K. Paul Holt President / CEO Central Texas AGC / Passed through K. Paul Holt	4/21/2022 / 4/28/2022	If you have details you wish to provide regarding review comments of the draft Solid Waste dumpster enclosures welcome your forwarding them to me in advance of the meeting. (Will also listen during the April 28 Developer's Meeting for understanding of these concerns.) / Solid Waste actually reduced the dumpster pad size in our previous review. We based dimensions off the size of dumpsters and amount of clearance needed. If the depth were to be reduce it is likely the dumpster or enclosure would receive damage at some point. K. Paul, I (Kody Petillo) would be more than willing to meet with you in advance of the next meeting to discuss this in more detail. If you are interested please give me some dates and times next week that would work for you. I can come to you.	Email & Webpage Spreadsheet / Email & Webpage Spreadsheet
2						
3						
4						