



NOTES:

1. THRUST BLOCKING UNDER ALL FITTINGS. REFERENCE W-3A TO W-3E. (MIN. 6 IN. OF CONCRETE AROUND ALL JOINTS (TYP.))
2. REFERENCE G8 AND G-10 FOR PIPE EMBEDMENT REQUIREMENTS.

DEEP SANITARY SEWER SERVICE CONNECTION

(NO SCALE)

DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.



**ENGINEERING
DIVISION**



| REVISIONS | | | |
|-----------|-------------|----|------------|
| NO. | COMMENTS | BY | DATE |
| | | | |
| | | | |
| | | | |
| | | | |
| ## | DESCRIPTION | FL | MO/DY/YEAR |

DATE
8/25/2021

S-3