



INSIDE WIDTH = OD PIPE + 12 IN. (MIN. 48 IN.)
 OUTSIDE WIDTH = INSIDE WIDTH + 18 IN. (MIN. 66 IN.)

NOTE:

1. USE SAME STEEL CONFIGURATION IN ALL WALLS.
2. SET MANHOLE AT CORNER NEAREST OUTLET PIPE BEARING ON TWO WALLS.
3. BRING TO FINISHED GRADE WITH 2 IN. CONCRETE THROAT RINGS (MIN. 6 IN., MAX 12 IN. HEIGHT) SET IN GROUT
4. FOR MANHOLE CONSTRUCTION IN STREET, REFERENCE ST-11 AND ST-12 FOR CONCRETE DIAMOND/PAD REQUIREMENTS

STANDARD STORM SEWER MANHOLE SECTION
(NO SCALE)

DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.



**ENGINEERING
DIVISION**



REVISIONS			
NO.	COMMENTS	BY	DATE
1	ADD INVERT NOTE	MZ	04/18/2022
##	DESCRIPTION	FL	MM/DD/YYYY

DATE
02/08/2022

SD-10