



PLAN VIEW

$B = ID \text{ LARGEST PIPE} + 12 \text{ IN.}, 36 \text{ IN. MINIMUM}$

**NOTE:**

1. THE CITY OF WACO PUBLIC WORKS DEPARTMENT ENGINEERING DIVISION MAY SUPPLY ONE "CITY OF WACO BENCHMARK" FOR PLACEMENT IN INLET TOP IN EITHER BACK CORNER.
2. THE CITY OF WACO PUBLIC WORKS DEPARTMENT ENGINEERING DIVISION BENCHMARKS SHALL BE PLACED AT A MAXIMUM SPACING OF 750 FT.
3. THE CITY OF WACO PUBLIC WORKS DEPARTMENT ENGINEERING DIVISION WILL PROVIDE THE BENCHMARKS. THE CONTRACTOR WILL COORDINATE WITH THE ENGINEERING INSPECTOR.

**STANDARD RECESSED INLET PLAN VIEW**

(NO SCALE)

DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.



**ENGINEERING  
DIVISION**



REVISIONS			
NO.	COMMENTS	BY	DATE
##	DESCRIPTION	FL	MM/DD/YYYY

DATE  
01/31/2022

**SD-5**