



$D = OD \text{ PIPE} + 12 \text{ IN. (36 IN. MIN)}$

NOTES:

1. STEEL IN END WALL SAME AS STEEL IN SIDE WALL.
2. LAP ALL CORNER BARS A MINIMUM OF 40 X REBAR DIAMETER.
3. SUPPORT POSTS SHALL BE SPACED MAXIMUM EVERY 5 FT.
4. USE SUPPORTS POSTS FOR INLETS 10 FT & LARGER.

STANDARD RECESSED INLET SIDE SECTION
(NO SCALE)

DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.



**ENGINEERING
DIVISION**



REVISIONS			
NO.	COMMENTS	BY	DATE
1	CHANGE INLET OPENING SIZE	MZ	10/24/2022
##	DESCRIPTION	FL	MM/DD/YYYY

DATE
01/31/2022

SD-6