



**NOTES:**

1. THIS METHOD SHALL BE USED WHEN THE CONCRETE VALVE/MANHOLE PAD/DIAMOND IS LESS THAN 2 FEET FROM THE LIP OF THE CONCRETE GUTTER.
2. IF POINT ON PERIMETER OF CONCRETE VALVE/MANHOLE PAD/DIAMOND IS WITHIN 2 FEET OF AN ADJACENT CONCRETE VALVE/MANHOLE PAD/DIAMOND COMBINE CONCRETE VALVE/MANHOLE PADS/CONCRETE DIAMONDS.
3. REFERENCE ST-11, ST-12, ST-13, ST-14, W-35, W-35, W-36, S-21, AND S-22 FOR ADDITIONAL DETAILS.

**CONCRETE PAD MODIFICATION EXAMPLES**  
(SHALL BE SHOWN IN PLANS CONSISTENT WITH THE STANDARD DETAILS)

DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.

(NO SCALE)



**ENGINEERING  
DIVISION**



REVISIONS			
NO.	COMMENTS	BY	DATE
##	DESCRIPTION	FL	MM/DD/YYYY

DATE  
05/02/2022

**ST-32**