

TOP OF CONCRETE TO BE AT BOTTOM OF BOLT THREADS

ANCHOR BOLTS PER MANUFACTURER. SEE NOTE 2 DETAIL T-2A

GRADE LEVEL

30 IN.

12 IN.

4 IN.

58 IN.

64 IN.

ANGLE IRON WELDED TO ANCHOR BOLTS

2 IN. PVC SCH. 40

SEE STANDARD DETAIL G-7 GENERAL CONCRETE & REINFORCEMENT NOTES

8' GROUND ROD

12 IN.

12 IN.

12 IN.

12 IN.

12 IN.

12 IN.

12 IN.

2 IN.

12 IN.

6 IN.

24 IN. Ø

REBAR WELDED CAGE

SHOE BOX STREET LIGHT REINFORCED FOUNDATION

SECTION VIEW

(NO SCALE)

DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.



ENGINEERING DIVISION



REVISIONS			
NO.	COMMENTS	BY	DATE
##	DESCRIPTION	FL	MM/DD/YYYY

DATE
07/01/2022

T-4