



NOTES:

1. STREET NAME SIGNS SHALL BE INSTALLED AT LOCATIONS SHOWN ON PLANS THAT ARE APPROVED BY CITY ENGINEER.
2. STREET NAME SIGN SHALL FACE EACH DIRECTION OF TRAFFIC.
3. SIGN BLADE BLANK SHALL BE A FLAT (I.E., NOT EXTRUDED) SHEET HAVING A MINIMUM THICKNESS OF 0.080 INCH. THE BLANK SHALL BE MADE OF ALUMINUM ALLOY THAT CONFORMS TO REQUIREMENTS OF ASTM B209 (FOR ALLOYS 5052-H38 OR 6061-T6) AND SHALL BE FREE OF DEFECT INCLUDING WARP, DENT, BURR, CORROSION, WHITE RUST, AND DIRT.
4. SIGN FACE MATERIALS SHALL CONFORM TO THE CURRENT "DEPARTMENTAL MATERIALS SPECIFICATION 8300" OF THE TEXAS DEPARTMENT OF TRANSPORTATION. MATERIALS SHALL CONSIST OF GREEN ELECTRONIC-CUTTABLE (EC) FILM OVER WHITE HIGH INTENSITY PRISMATIC (HIP) RETROFLECTIVE SHEETING. EC FILM SHALL BE 1177C GREEN, AVERY DENNISON OL-2007 GREEN, OR EQUIVALENT. HIP SHEETING SHALL CONFORM TO REQUIREMENTS OF ASTM D4956 (TYPE III HIP) OR AASHTO M268 (E.G., AVERY DENNISON OMNICUBE T-11500 WHITE OR EQUIVALENT).
5. SIGN FACE SHALL HAVE WHITE LETTERING ON A GREEN BACKGROUND AND SHALL HAVE A 1/2 INCH WIDE WHITE BORDER.
6. LETTERING FONT (TYPEFACE) SHALL BE CLEARVIEW.
7. STREET NAME SHALL BE CENTER-JUSTIFIED AND SHALL HAVE AN UPPERCASE FIRST LETTER FOLLOWED BY LOWERCASE LETTERS. UPPERCASE LETTERS SHALL BE AT LEAST 5 INCHES TALL. LOWERCASE LETTERS SHALL BE AT LEAST 4 INCHES TALL.
8. STREET NAME DIRECTIONAL PREFIX (E.G., N, S) SHALL BE LEFT-JUSTIFIED, UPPERCASE, AND 2.5 INCHES TALL.
9. STREET NAME SUFFIX SHALL BE RIGHT-JUSTIFIED, ABBREVIATED, AND 2.5 INCHES TALL. THE SUFFIX SHALL HAVE AN UPPERCASE FIRST LETTER FOLLOWED BY LOWERCASE LETTERS. ACCEPTABLE ABBREVIATIONS INCLUDE: Ave, Blvd, Cir, Ct, Dr, Hwy, Pkwy, Pl, Plz, Rd, St, Ter, AND Trl.
10. STREET NUMBER SUFFIX (E.G., nd, th) SHALL BE LOWERCASE AND 2.5 INCHES TALL.
11. EVERY STREET NAME SIGN SHALL HAVE A BEGINNING BLOCK NUMBER. THE NUMBER SHALL BE RIGHT-JUSTIFIED AND 2.5 INCHES TALL.

STREET NAME SIGN BLADE
(FOR LOCAL AND RESIDENTIAL COLLECTOR STREETS)
 (NO SCALE)

DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.



**ENGINEERING
DIVISION**



REVISIONS			
NO.	COMMENTS	BY	DATE
##	DESCRIPTION	FL	MM/DD/YYYY

DATE
07/01/2022

T-7