

NOTES:

- MINIMUM DIMENSIONS PROVIDED. CONTRACTOR SHALL INCREASE AS NEEDED TO ADJUST OR REPLACE VALVE BOX.
- 2. SAWCUT EDGE OF EXISTING PAVEMENT ON ALL SIDES OF VALVE BOX TO PRODUCE A SMOOTH AND EVEN EDGE FOR SURFACE REPLACEMENT.
- 3. ANY OLD STYLE VALVE BOXES SHALL BE REPLACE WITH A NEW VALVE BOX AND LID PER CITY OF WACO DETAIL DETAILS $\underline{\text{W-6}}, \underline{\text{W-7}}, \text{AND } \underline{\text{W-8}}.$
- 4. ANY EXISTING VALVE BOXES DAMAGED BY CONSTRUCTION SHALL BE REPLACED AT CONTRACTOR'S EXPENSE WITH A BOX THAT MEETS THE CITY OF WACO DETAILS W-6, W-7, AND W-8.
- 5. VALVE BOX LID SHALL BE FLUSH WITH FINISHED PAVEMENT SURFACE. MAX TOLERANCES +/- 1/8 INCH.

GATE VALVE BOX ADJUSTMENT OR REPLACEMENT (PRESERVATION WORK ONLY)

(NO SCALE)



ENG	INE	ER	ING	DIV	ISI	ON
ISCLAIMER:	THE USE	OF THIS S	TANDARD	IS GOVERN	ED BY TI	HE "TEXAS
NGINEERING	PRACTICE	ACT". N	O WARRAN	ITY OF ANY	KIND IS	MADE BY

ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.

REVISIONS					
NO.	COMMENTS	BY	DATE		
				ı	
				L	
				Г	
				ı	
				ı	
##	DESCRIPTION	FL	MM/DD/YYYY		

DATE 11/15/2024

ST-46