

## ASPHALT SURFACE AREAS AND RATES FOR TRAVEL LANES

DESCRIPTION	RATE	BASIS	QUANTITIES
<b>SEAL COAT</b>			
<b>FIRST COURSE</b>			
ASPH (AC-20-XP)	0.40 GAL / SY <sup>#</sup>	____,____ SY	____,____ GAL
AGGR (TY-PB GR-3)	1 CY / 90 SY	____,____ SY	____ CY
<b>SECOND COURSE</b>			
ASPH (AC-20-XP)	0.28 GAL / SY <sup>#</sup>	____,____ SY	____,____ GAL
AGGR (TY-PB GR-4 SAC-B)	1 CY / 120 SY	____,____ SY	____ CY

# RATE MAY BE VARIED BY ENGINEER OF RECORD DEPENDING ON FIELD CONDITIONS AND OTHER FACTORS IN ADVANCE OF MANDATORY PRE-SURFACING MEETING WITH APPROVAL OF THE CITY.

**NOTES:**

1. ASPHALT SHALL ONLY BE PLACED JUNE 1 THROUGH AUGUST 31 UNLESS OTHERWISE APPROVED BY THE CITY.
2. PLACE FIRST COURSE SEAL COAT USING AC-20-XP ASPHALT ON PRIMED SURFACE (OR EXISTING ASPHALTIC SURFACE) AT A RATE OF 0.40 GAL / SY (UNDERSTANDING RATE MAY REQUIRE MODIFYING BASED ON FIELD CONDITIONS AND OTHER FACTORS)<sup>#</sup> AND IMMEDIATELY COVER WITH AGGR (TY-PB GR-3) AT RATE OF 1 CY / 90 SY, ROLL, CURE, AND SWEEP.
3. PLACE SECOND COURSE SEAL COAT ON FIRST COURSE SEAL COAT USING AC-20-XP ASPHALT AT A RATE 0.28 GAL / SY (UNDERSTANDING RATE MAY REQUIRE MODIFYING BASED ON FIELD CONDITIONS AND OTHER FACTORS)<sup>#</sup> AND IMMEDIATELY COVER WITH AGGR (TY-PB GR-4 SAC-B) AT RATE OF 1 CY / 120 SY, ROLL, CURE, AND SWEEP.
4. MATERIALS AND WORK SHALL BE IN ACCORDANCE WITH CURRENT TXDOT SPECIFICATIONS.

## SEAL COAT SURFACING FOR DEVELOPER PROJECTS

(USE REQUIRES MODIFICATION BY ENGINEER OF RECORD FOR BASIS & QUANTITIES AND APPROVAL BY THE CITY)



## ENGINEERING DIVISION

**DISCLAIMER:** THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.

REVISIONS			
NO.	COMMENTS	BY	DATE
##	DESCRIPTION	FL	MM/DD/YYYY

DATE  
11/15/2024

ST-47