



SP 5.4-001 (2013)

Standard Specifications for Construction City of Waco 2013 Special Provision Section 5.4 Concrete Sidewalks and Driveway Approaches

October 6, 2022

The Standard Specifications for Construction City of Waco 2013
Section 5.4 Concrete Sidewalks and Driveway Approaches

Part 2: Product

A. Materials

3. Slump

is hereby deleted and replaced in its entirety as follows effective for all City projects with bid opening date of December 1, 2022 and thereafter; Developer projects with preconstruction meeting date of December 1 and thereafter; and for right-of-way permits issued December 1 and thereafter to Permittees for work without a preconstruction meeting:

PART 2: PRODUCT

A. MATERIALS

3. Slump – The placement of concrete shall comply with the specifications and latest edition of ACI SPEC-301. Unless otherwise specified, concrete shall be placed at a 4" slump, plus or minus 1". No water shall be added after the load has been slumped, inspected, and tested. Concrete shall be vibrated where possible.

Thomas M. Dahl
Thomas M. Dahl, P.E.