

External Review Comment Received and Response for Standard Details Published April 19

No.	Standard Detail Alpha-Numeric	Comment	By	Date	Response by Multi-departmental Interdisciplinary Team Germane Members	Means
1	ST-1	<p>For ST-1, note 15a: "A. THE PARKWAY SHALL BE THAT SPACE BETWEEN THE FACE OF THE STREET CURB AND THE PROPERTY LINE. THIS PARKWAY SHALL HAVE A MINIMUM SLOPE OF ONE-QUARTER OF AN INCH PER ONE FOOT AND A MAXIMUM SLOPE OF ONE-HALF OF AN INCH PER ONE FOOT TOWARD THE STREET"</p> <p>I know this is in the City ordinances, but if this parkway area requires a sidewalk it's standard practice to form at less than maximum cross-slope to ensure ADA compliance. If one was to follow this to a T you'd have a hard time ensuring ADA compliance of sidewalks. I'd suggest revising the minimum slope to 1/8" per foot minimum.</p>	Travis T. Whitis, P.E. Yalgo Engineering, LLC (254) 258-4616	2/29/2024	Added note, " <i>This excludes components of ADA pedestrian access routes & shared use paths, drive approaches, and other approved identified infrastructure within the parkway.</i> "	email followed by later linking on City website Standard Details Listing
2						
3						
4						
5						