

NOTES:

- 1. EROSION CONTROL BLANKETS SHALL NOT BE USED ON SLOPES GREATER THAN 2:1 OR IN CHANNELS WITH SHEAR STRESSES GREATER THAN 2.0 POUNDS PER SQUARE FOOT
- 2. PRIOR TO THE INSTALLATION OF ANY EROSION CONTROL BLANKETS, ALL ROCKS, DIRT CLODS, STUMPS, ROOTS, TRASH, AND ANY OTHER OBSTRUCTIONS THAT WOULD PREVENT THE BLANKET FROM LYING IN DIRECT CONTACT WITH THE SOIL SHALL BE REMOVED. ANCHOR TRENCHING SHALL BE LOCATED ALONG THE ENTIRE PERIMETER OF THE INSTALLATION AREA, EXCEPT FOR SMALL AREAS WITH LESS THAN 2% SLOPE.
- 3. INSTALLATION AND ANCHORING SHALL CONFORM TO THE RECOMMENDATIONS WITHIN THE MANUFACTURE PUBLISHED LITERATURE FOR THE APPROVED EROSION CONTROL BLANKET. PARTICULAR ATTENTION MUST BE PAID TO JOINTS AND OVERLAPPING MATERIAL.
- 4. IN THE ABSENCE OF MANUFACTURE'S LITERATURE, A MINIMUM 11-GAUGE WIRE STAPLES, 6-INCHES IN LENGTH AND 1-INCH WIDTH WILL BE USED.
- 5. AFTER APPROPRIATE INSTALLATION, THE BLANKETS SHOULD BE CHECKED FOR UNIFORM CONTACT WITH THE SOIL, SECURITY OF THE LAP JOINTS, AND FLUSHNESS OF THE STAPLES WITH THE GROUND.
- 6. REGULAR INSPECTION SHALL OCCUR TO REPLACE OR RE-ANCHOR LOOSENED BLANKETS AND TO REMOVE SEDIMENT DEPOSITED ON BLANKETS.
- 7. INSPECTION SHALL BE SPECIFIED IN THE SWPPP.

EROSION CONTROL BLANKET (ECB) DETAILS

(NO SCALE)



	ENGINEERING DIVISION		REVISIONS	DATE		
	ENGINEERING DIVISION	NO.	COMMENTS	BY	DATE	01/01/2024
	DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS			_		01/01/2024
	ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY					
	THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO					
	ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD					
-	TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES					VVF-0
7	RESULTING FROM ITS USE.	##	DESCRIPTION	EI	MM/DD/VVVV	