



CITY OF WACO

Date: April 05, 2023
RFP No: RFB 2023-015
Commodity: 2023 Street Preservation Phase 1
Contact: pcampos@wacotx.gov

Closing Time: 2:00 P.M., (CT) April 12, 2023
Opening Time: 2:01 P.M., (CT) April 12, 2023

Addendum No: 2

The above-mentioned bid invitation has been changed in the following manner. **Sign and return addendum to the Purchasing Office by the closing time and date with your RFB response.** Returning this page signed by your authorized agent will serve to acknowledge this change. All other requirements of the invitation remain unchanged. If you have any questions, please call or stop by the Purchasing Office at the above address.

THE FOLLOWING IS BEING ISSUED AS ADDENDUM NO. 2

• **Question(s) and Response(s).**

Question:

1. Per Section 350 (TXDOT) will the contractor be required to use a continuous slurry mixing unit (Continuously mixes and lays materials-typically used for highways) or will truck-mount slurry mixing units (typically used on city streets) be accepted?

City of Waco Response:

1. Yes, per TxDOT Item 350, the Contractor will be required to use a continuous slurry mixing machine. A few exceptions will be permitted in tight places, such as cul-de-sacs, where a truck-mounted slurry mixing machine may be used.

Firm: _____

Address _____

Signature of Person
Authorized to Sign Bid: _____

Signor's Name and Title
(print or type): _____

Date: _____ Telephone: _____ Fax: _____