# **PEDESTRIAN MEDALLION PATHS - GENERAL NOTES**

## GENERAL

- 1. ALL CONCRETE AND REINFORCEMENT MATERIALS AND PLACEMENT MUST COMPLY WITH SECTION 5.1 OF THE CITY OF WACO STANDARD SPECIFICATIONS FOR CONSTRUCTION.
- 2. PLEASE REFER TO CITY OF WACO MANUAL OF STANDARD DETAILS G-7 FOR GENERAL CONCRETE AND REINFORCEMENT NOTES.

### LOCATION

3. LOCATION INTENDED FOR SELECTED SIDEWALK IN DOWNTOWN DISTRICT WITH C-4 ZONING. SUBMITTALS MUST BE REVIEWED AND APPROVED BY PLANNING.

### CONSTRUCTION

- 4. TOOL ALL EXPOSED EDGES (TYPICAL).
- 5. PEDESTRIAN MEDALLION PATHS AT CROSSWALKS SHALL BE INSTALLED TO MATCH EXISTING STREET CROSS SLOPE. H.M.A.C. LEVEL-UP SHALL BE PLACED SO AS TO PROVIDE A SMOOTH TRANSITION. CONTRACTOR SHALL VERIFY THAT THE PEDESTRIAN CROSSING AND LEVEL-UP WILL ALLOW POSITIVE STREET DRAINAGE.
- 6. SAW CUT AND REMOVE EXISTING PAVEMENT AS REQUIRED FOR SMOOTH TRANSITION.
- 7. SAKRETE<sup>®</sup> PAVER SET POLYMERIC SAND<sup>TM</sup> SHALL BE CLEANED FROM TOP OF BRICKS AND WALKWAY.

#### PAVEMENT AND SIDEWALK LEVEL ALIGNMENT:

- 8. FOR MAINLINE PAVEMENTS IN LONGITUDINAL DIRECTION, THE GAP BELOW A 10 FT. UNLEVELED STRAIGHT EDGE RESTING ON HIGH SPOTS SHALL NOT EXCEED 1/8 IN.
- 9. FOR MAINLINE PAVEMENTS IN TRANSVERSE DIRECTION, THE GAP BELOW A 10 FT. UNLEVELED STRAIGHT EDGE RESTING ON HIGH SPOTS SHALL NOT EXCEED 1/4 IN.
- 10. FOR RAMPS, SIDEWALKS, AND INTERSECTIONS, IN ANY DIRECTION, THE GAP BELOW A 10 FT. UNLEVELED STRAIGHT EDGE RESTING ON HIGH SPOTS SHALL NOT EXCEED 1/4 IN.

		REVISIONS				DATE
	ENGINEERING DIVISION	NO.	COMMENTS	BY	DATE	
	DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS					01/01/2024
	ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY					
	THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO					_
CITYOF	ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD					
	TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES					
	RESULTING FROM ITS USE.	##	DESCRIPTION	FL	MM/DD/YYYY	