

- 2. LAP ALL CORNER BARS A MINIMUM OF 40 X REBAR DIAMETER.
- 3. SUPPORT POSTS SHALL BE SPACED MAXIMUM EVERY 5 FT.
- 4. USE SUPPORTS POSTS FOR INLETS 10 FT & LARGER.
- 5. SHAPE INVERT OF M.H. WITH 2000 PSI CONCRETE (3000 PSI CONCRETE MAY BE SUBSTITUTED)
- 6. IN ACCORDANCE WITH G-7 NOTE 6. SUBGRADE SHALL BE COMPACTED TO 95% STANDARD PROCTOR DENSITY AT ± 2% OPTIMAL MOISTURE CONTENT.
- 7. IN ACCORDANCE WITH <u>SD-1</u> NOTE 21 PRECAST INLETS SHALL BE BEDDED WITH MIN. 6 IN. DEPTH OF AGGREGATE MEETING ASTM 57 SPECIFICATIONS TO A MINIMUM DISTANCE OF 12 IN. OUTSIDE PERIMETER.

STANDARD INLET SIDE SECTION

(NO SCALE)



ENCINEEDING DIVICION		REVISIONS	DATE		
ENGINEERING DIVISION	NO.	COMMENTS	BY	DATE	
DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY					01/01/2024
THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD					CD 4
TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.	##	DESCRIPTION	FL	MM/DD/YYYY	SD-4