

NOTES:

- 1. SWEATED, GALVANIZED, OR PVC JOINTS SHALL NOT BE ACCEPTED. NON-LEAD BRASS, COPPER TUBING WITH COMPRESSION COUPLINGS, OR POLY PIPE WITH STAINLESS STEEL INSERTS WILL BE ACCEPTED.
- 2. EROSION CONTROL AND AREA DRAINAGE MEASURES AT FLUSHING VALVE DISCHARGE MUST BE INSTALLED TO MEET SITE CONDITIONS.
- 3. DISCHARGE OF CHLORINATED WATER MUST COMPLY WITH TCEQ REQUIREMENTS.
- 4. INSTALL 2 IN. BALL CORP STOP INTO END CAP, SO IF MAIN IS EXTENDED, CAP AND 2 IN. STOP CAN BE REMOVED.
- 5. THE METER IS TO BE LOCATED AS CLOSE TO THE MAIN AS POSSIBLE. (MIN. 24 IN. CLEARANCE). LOCATIONS SHOULD BE REVIEWED BY THE INSPECTOR ASSIGNED TO THE PROJECT FROM THE CITY OF WACO. ANY VARIATION SHALL BE APPROVED BY CITY ENGINEER PRIOR TO INSTALLATION.

DEAD END WATER MAIN AUTOMATIC FLUSHING VALVE

(NO SCALE)

	REVISIONS				DATE
N	0.	COMMENTS	BY	DATE	
EVAC					01/01/2024
DARD					VVI JE
AGES					VV-ZO
#	#	DESCRIPTION	FL	MM/DD/YYYY	
	TEXAS DE BY WACO IDARD IAGES	TEXAS DE BY WACO IDARD IAGES	No. COMMENTS	NO. COMMENTS BY	NO. COMMENTS BY DATE TEXAS