

NOTES:

- 1. MINIMUM PIPE SIZE OF RING CONNECTION SHALL MATCH PIPE SIZE OF SMALLER MAIN.
- GATE VALVES, TEES AND BENDS REQUIRE BLOCKING. SEE HORIZONTAL BLOCKING TABLES ON <u>W-3A, W-3B, W-3C, W-3D, AND W-3E</u>.
- 3. GATE VALVE SHALL BE INSTALLED ON LARGER WATER MAIN TEE.

RING CONNECTION

(NO SCALE)

