

- THIS DETAIL NEED NOT TO BE APPLIED FOR CROSSINGS INVOLVING SEWER SERVICE CONNECTIONS.
- CENTER 18 FT. MIN. SECTION OF SEWER PIPE UNDER STORMWATER DRAINAGE CONDUIT OR FRANCHISE UTILITY PIPE. SEWER LINE SHALL BE PVC PRESSURE- RATED AT 150 PSI MIN.
- CITY STANDARD CONTROLLED LOW STRENGTH MATERIAL (CLSM).

EMBEDMENT FOR NEW SEWER CROSSING UNDER NEW OR EXISTING STORMWATER DRAINAGE CONDUIT OR FRANCHISE UTILITY LINE

(NO SCALE)



ENGINEERING DIVISION	
DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXA	S
ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE B	Υ
THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WAC	0
ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDAR	D
TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGE	S

ENGINEERING DIVISION

DATE			REVISIONS	
	DATE	BY	COMMENTS	NO.
01/01/2024				•
C 22				
3- 23				
	MM/DD/YYYY	FL	DESCRIPTION	##