



NOTES:

1. IN ACCORDANCE WITH [G-7](#) NOTE 6. SUBGRADE SHALL BE COMPACTED TO 95% STANDARD PROCTOR DENSITY AT $\pm 2\%$ OPTIMAL MOISTURE CONTENT.
2. IN ACCORDANCE WITH [SD-1](#) NOTE 21 PRECAST INLETS SHALL BE BEDDED WITH MIN. 6 IN. DEPTH OF AGGREGATE MEETING ASTM 57 SPECIFICATIONS TO A MINIMUM DISTANCE OF 12 IN. OUTSIDE PERIMETER.

STANDARD INLET FRONT SECTION VIEW (NO SCALE)



ENGINEERING DIVISION

DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.

REVISIONS			
NO.	COMMENTS	BY	DATE
1	MODIFY OUTFLOW PIPE PLACEMENT	MZ	04/19/2024
##	DESCRIPTION	FL	MM/DD/YYYY

DATE
01/01/2024

SD-3