

24 IN.

24 IN. MIN.

INDIRECT FLOW

NOTES:

- 1. CURB AND GUTTER SHALL BE PLACED SEPARATELY AFTER BASE OR 2,000 PSI CONCRETE HAS CURED.
- 2. TYPE "A" MATERIAL PER STANDARD SPECIFICATIONS FOR CONSTRUCTION SECTION 4.2 EXCAVATION AND BACKFILL PART 2: PRODUCT A. MATERIALS 3. TRENCH BACKFILL A. TYPE "A" MATERIAL MECHANICALLY COMPACTED TO 95% OF THE MAXIMUM DRY DENSITY (TEX-113-E).
- 3. HMAC SHALL BE TYPE D FOR STREET CLASSIFICATION LOCAL AND RESIDENTIAL COLLECTOR.

24 IN.

- 4. HMAC SHALL BE TYPE C OR TYPE D FOR STREET CLASSIFICATION OF COMMERCIAL COLLECTOR AND INDUSTRIAL COLLECTOR. FOR INDUSTRIAL COLLECTOR DEPTH OF HMAC SHALL BE 3 INCHES.
- 5. ORIGINAL PLACEMENT OF CURB & GUTTER AND REPLACEMENT OF CURB & GUTTER SHALL BE IN ACCORDANCE WITH THIS STANDARD DETAIL UNLESS SHOWN OTHERWISE IN PLANS APPROVED BY THE CITY.

STANDARD CURB & GUTTER PLACEMENT AND REPLACEMENT DETAILS

(USE FOR EXISTING STREETS ONLY) (NO SCALE)



ENGINEERING DIVISION	NO.	REVISIONS COMMENTS	BY	DATE	DATE 01/01/2024
DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES					ST-20
RESULTING FROM ITS USE.	##	DESCRIPTION	FL	MM/DD/YYYY	0.20