

 THE ASSEMBLY SHALL BE READILY ACCESSIBLE FOR TESTING AND MAINTENANCE, WITH A MINIMUM CLEARANCE OF 12 IN. ALL AROUND THE ASSEMBLY.

## PRESSURE REDUCING VALVE ASSEMBLY ON NEW OR EXISTING MAIN

(NO SCALE)

SEE W-24B FOR ADDITIONAL NOTES

	ENGINEERING DIVISION	REVISIONS				DATE
		NO.	COMMENTS	BY	DATE	01/01/2024
	THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO					
CITYOF	ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD					I \
	TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES					VV-Z4A
	RESULTING FROM ITS USE.	##	DESCRIPTION	FL	MM/DD/YYYY	