


PLAN VIEW



SECTION VIEW

NOTES:

1. A 1 IN. X 4 IN. BOARD SECURED WITH $\frac{1}{4}$ IN. OR $\frac{3}{8}$ IN. \varnothing CONCRETE SCREWS OF SUFFICIENT LENGTH. THE SCREWS SHALL BE ATTACHED TO THE GUTTER AND INLET TOP BY DRILLING AN APPROPRIATE PILOT HOLE WITH A CONCRETE BIT AND INSERTING PLASTIC FASTENERS. THE TOP OF THE SCREW SHALL BE RECESSED BELOW THE TOP OF THE BOARD. THE SCREWS SHALL BE PLACED ON 3 FT. O.C. UPON REMOVAL, EITHER LEAVE THE PLASTIC FASTENERS IN PLACE, OR REMOVE THE PLASTIC FASTENERS. CLEAN ANY DIRT/DEBRIS FROM THE SCREW LOCATIONS, APPLY CHEMICAL SANDING AGENT AND APPLY NON-SHRINK GROUT FLUSH WITH THE SURFACE OF THE GUTTER. SEE NOTE 6 AND THIS DRAWING FOR ALTERNATE.
2. A SECTION OF FILTER FABRIC SHALL BE REMOVED TO ALLOW A 3 INCH OPENING FROM TOP OF INLET OPENING TO TOP OF FILTER FABRIC OR AS DIRECTED BY THE ENGINEER OR DESIGNATED REPRESENTATIVE. FABRIC MUST BE SECURED TO WIRE BACKING WITH CLIPS OR HOG RINGS AT THIS LOCATION.
3. DAILY INSPECTION SHALL BE MADE BY THE CONTRACTOR AND SILT ACCUMULATION MUST BE REMOVED WHEN DEPTH REACHES 2 INCHES.
4. CONTRACTOR SHALL MONITOR THE PERFORMANCE OF INLET PROTECTION DURING EACH RAINFALL EVENT AND IMMEDIATELY REMOVE THE INLET PROTECTIONS IF THE STORMWATER BEGINS TO OVERTOP THE CURB.
5. INLET PROTECTIONS SHALL BE REMOVED AS SOON AS THE SOURCE OF SEDIMENT IS STABILIZED.
6. IF BAGS ARE USED INSTEAD OF THE SECURING BY BOARD AS DESCRIBED IN NOTE 1, THEN THEY SHALL BE PLACED AS SHOWN INCLUDING IN GUTTER AT CENTER OF EACH INLET TOP SUPPORT POST PLACED EVERY 5 FT. PER SD-4, NOTE 4.

FILTER WEIR CURB INLET PROTECTION

(NO SCALE)

SEE [WP-7A](#) FOR
ADDITIONAL DETAILS



ENGINEERING DIVISION

DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.

REVISIONS			
NO.	COMMENTS	BY	DATE
1	MODIFY PLAN AND SECTION VIEWS TO PROVIDE MORE DETAIL; MODIFY NOTES 1& 2; ADD NOTE 6	MZ	04/19/2024
##	DESCRIPTION	FL	MM/DD/YYYY

DATE
01/01/2024

WP-7B