



PLAN VIEW

INTERIOR WIDTH = OUTSIDE DIAMETER OF LARGEST PIPE + 12 IN., 36 IN. MINIMUM

NOTE:

1. THE CITY OF WACO PUBLIC WORKS DEPARTMENT ENGINEERING DIVISION MAY SUPPLY ONE "CITY OF WACO BENCHMARK" FOR PLACEMENT IN INLET TOP IN EITHER BACK CORNER.
2. THE CITY OF WACO PUBLIC WORKS DEPARTMENT ENGINEERING DIVISION BENCHMARKS SHALL BE PLACED AT A MAXIMUM SPACING OF 750 FT, AND WILL BE PROVIDED BY THE CITY OF WACO PUBLIC WORKS DEPARTMENT. THE CONTRACTOR SHALL COORDINATE WITH THE ENGINEERING INSPECTOR.

STANDARD RECESSED INLET PLAN VIEW
(NO SCALE)



ENGINEERING DIVISION

DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.

REVISIONS			
NO.	COMMENTS	BY	DATE
1	REVISE OUTFLOW PIPE LOCATION & ADD NOTE; MODIFY INTERIOR DIMENSION; MODIFY COVER	MZ	04/19/2024
##	DESCRIPTION	FL	MM/DD/YYYY

DATE
01/01/2024

SD-5