

NOTES:

- 1. SHALL BE USED FOR SEWER DEPTHS GREATER THAN 10 FT.
- 2. THRUST BLOCKING UNDER ALL FITTINGS. REFERENCE <u>W-3A, W-3B, W-3C, W-3D, AND W-3E</u>. (MIN. 6 IN. OF CONCRETE AROUND ALL JOINTS (TYP.)
- 3. REFERENCE <u>G-8</u> AND <u>G-10</u> FOR PIPE EMBEDMENT REQUIREMENTS.

DEEP SANITARY SEWER SERVICE CONNECTION

(NO SCALE)



TENOMETERING BUMBION	REVISIONS				DATE
ENGINEERING DIVISION	NO.	COMMENTS	BY	DATE	
DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS			-		01/01/2024
ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO					
ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD					S_3
TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES	ш	DECORIDATION	-	MM/DDAGGG	<u> </u>