

NOTES:

- USE SAME STEEL CONFIGURATION IN ALL WALLS. SET MANHOLE RISER SO THAT IT BEARS ON THE WALL CENTERED OVER OUTLET PIPE. IN ACCORDANCE WITH G-7 NOTE 6. SUBGRADE SHALL BE COMPACTED TO 95% STANDARD PROCTOR DENSITY AT ± 2% OPTIMAL
- MOISTURE CONTENT. IN ACCORDANCE WITH SD-1 NOTE 21 PRECAST INLETS SHALL BE BEDDED WITH MIN. 6 IN. DEPTH OF AGGREGATE MEETING ASTM 57

SPECIFICATIONS TO A MINIMUM DISTANCE OF 12 IN. OUTSIDE PERIMETER.

DEEP STORMWATER DRAIN MANHOLE SECTION VIEW

(NO SCALE)



ENGINEEDING DIVICION		REVISIONS	DATE		
ENGINEERING DIVISION	NO.	COMMENTS	BY	DATE	
DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS					01/01/2024
ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO			-		
ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD					SD 43
TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES					SD- Z
RESULTING FROM ITS USE.	##	DESCRIPTION	FL	MM/DD/YYYY	

DATE