

NOTES:

- (1) SAW CUT EDGE OF EXISTING PAVEMENT FULL DEPTH OF CONCRETE ON ALL SIDES OF PROPOSED TRENCH TO PRODUCE A SMOOTH AND EVEN EDGE FOR TRENCH EXCAVATION. EXISTING PAVEMENT SHOULD BE REMOVED TO CLEAN, STRAIGHT LINES PARALLEL AND PERPENDICULAR TO THE FLOW OF TRAFFIC.
- (2) SEE G-7, G-8, G-9, AND G-10 FOR MATERIALS REQUIREMENTS AND INSTALLATION.
- UPON COMPLETION OF PLACEMENT OF MATERIAL IN NOTE 2, SAW CUT EXISTING PAVEMENT FULL DEPTH OF CONCRETE TO PRODUCE A SMOOTH AND EVEN EDGE FOR CONCRETE PAVEMENT REPLACEMENT. EXISTING PAVEMENT SHOULD BE REMOVED TO CLEAN STRAIGHT LINES PARALLEL AND PERPENDICULAR TO THE FLOW OF TRAFFIC. DO NOT CONSTRUCT PATCH WITH ANGLED SIDES AND IRREGULAR SHAPES.
- (4) SEE <u>ST-35</u> AND/OR <u>ST-36</u> FOR LIMITS OF THIS SAW CUTTING.
- (5) #5 X 24 IN. DEFORMED DOWELS AT 12 IN. O.C. PLACED IN 3/4 IN. DRILLED HOLES BLOWN CLEAN. COAT DOWELS WITH EPOXY RESIN, FILL HOLES WITH EXPOXY RESIN, AND SUPPORT DOWELS IN CENTER OF HOLE UNTIL EPOXY HAS CURED.
- (6) #4 REBARS @ 12 IN. OCEW
- (7) CONCRETE FOR PAVING SHALL BE IN ACCORDANCE WITH <u>ST-1</u>. THICKNESS SHALL BE 8 IN. OR MATCH EXISTING CONCRETE PAVEMENT THICKNESS WHICHEVER IS GREATER.

CLASS D (CONCRETE) PAVEMENT REPLACEMENT, TRENCH BACKFILL AND EMBEDMENT

(NO SCALE)



ENGINEERING DIVISION ISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXA

| DISCLAIMER: THE USE OF THIS STANDARD IS GO | OVERNED BY THE "TEXAS |
|--------------------------------------------|------------------------|
| ENGINEERING PRACTICE ACT". NO WARRANTY (| OF ANY KIND IS MADE BY |
| THE CITY OF WACO FOR ANY PURPOSE WHATSOE | VER. THE CITY OF WACO |
| ASSUMES NO RESPONSIBILITY FOR THE CONVER | SION OF THIS STANDARD |
| TO OTHER FORMATS OR FOR INCORRECT | RESULTS OR DAMAGES |
| RESULTING FROM ITS USE. | |

| | REVISIONS | | | |
|-----|-------------|----|-----------------|----------------------|
| NO. | COMMENTS | BY | DATE | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| ## | DESCRIPTION | FL | MM/DD/YYYY | |
| | | | NO. COMMENTS BY | NO. COMMENTS BY DATE |

DATE 01/01/2024

ST-37