


- NOTES:**
1. USE SAME STEEL CONFIGURATION IN ALL WALLS. SET MANHOLE RISER SO THAT IT BEARS ON THE WALL CENTERED OVER OUTLET PIPE.
 2. IN ACCORDANCE WITH [G-7](#) NOTE 6. SUBGRADE SHALL BE COMPACTED TO 95% STANDARD PROCTOR DENSITY AT ± 2% OPTIMAL MOISTURE CONTENT.
 3. IN ACCORDANCE WITH [SD-1](#) NOTE 21 PRECAST INLETS SHALL BE BEDDED WITH MIN. 6 IN. DEPTH OF AGGREGATE MEETING ASTM 57 SPECIFICATIONS TO A MINIMUM DISTANCE OF 12 IN. OUTSIDE PERIMETER.

DEEP STORMWATER DRAIN MANHOLE SECTION VIEW
(NO SCALE)

| | | | | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|---------------------------------------------------------|--|--|--------------------|
|  | ENGINEERING DIVISION | REVISIONS | | | DATE 01/01/2024 |
| | | NO. COMMENTS BY DATE | | | |
| DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE. | | 1 MODIFY PIPE AND CONCRETE MZ 04/19/2024 | | | SD-12 |
| | ## DESCRIPTION FL MM/DD/YYYY | | | | |