

**Sheet by Sheet Highlights of Updates Reflected in  
April 20, 2022 Draft, Sanitary Sewer, Traffic, Water, and  
Watershed Protection Standard Details  
To Be Used in Conjunction with the Draft Standard Details**

**S-23 Embedment For New Sewer Crossing Under New Or Existing Stormwater Drainage Conduit or Franchise Utility Line (new):**

1. New for use on relevant projects.

**S-24A Lift Station – Well & Valve Vault (replaces former S-11A previously removed while this was under development):**

1. Comprehensive updates for use on relevant projects.

**S-24B Lift Station – Wet Well & Valve Vault (replaces former S-11B previously removed while this was under development):**

1. Comprehensive updates for use on relevant projects.

**T-1 Traffic Control Plans:**

1. Comprehensive updates including items listed below.
2. Updated General Requirements.
3. Updated TCP submittal email address for non-City projects including Permittees.
4. Updated TCP submittal for City projects by adding link to City of Waco Projectmates portal.
5. Combined collectors and arterials into one heading.
6. Added TCP Implementation including, *“Contractor shall provide a designated Contractor’s Responsible Person (CRP) for implementation and maintenance of implemented traffic control plan.”*
7. Provided training requirement for Contractor and provided link to training.

**T-2A Antique/Shoebox Light & Assoc. Items Specs. (LED) (formerly T-2):**

1. Minor graphics edits for clarity.

**T-2B Antique/Shoebox Light & Assoc. Items Specs. (LED) (formerly T-2A):**

1. Updated recommended Onkor approved service pedestals.
2. Added, *“Minimum conductor size shall be 10 AWG.”*
3. Added, *“Foundation shall be positioned with outside edge a minimum of 2 FT. from back of curb.”*

**T-2C Antique/Shoebox Light & Assoc. Items Specs. (LED) (formerly T-2B):**

1. Updated ground (junction) boxes information.

**T-3 Antique Street Light Reinforced Foundation:**

1. Provided information for size of anchor bolts.

**T-4 Shoe Box Street Light Reinforced Foundation:**

1. Provided information for size of anchor bolts.

**T-5 Milbank Service Pedestal (formerly T-8):**

1. Minor graphics edits for clarity.

**T-6 Sign Post Installation (formerly T-9):**

1. Provided note regarding supplemental sign(s).

**T-7 Street Name Sign Blade (formerly T-11):**

1. Removed text from note 11., *“Obtain number from planning Department ...”*

**T-8 High-Visibility Longitudinal Crosswalk at Controlled Approach (new):**

1. New for use on relevant projects.

**W-37 Embedment for New Stormwater Drainage Conduit Or Franchise Utility Line (new):**

1. New for use on relevant projects.

**WP-8 Erosion Control Blanket (ECB) Details (new):**

1. New for use on relevant projects.