



## SP 4.7-003 (2013)

# Standard Specifications for Construction City of Waco 2013 Special Provision to Section 4.7 Piping Materials

February 16, 2016

The Standard Specifications for Construction City of Waco 2013  
Section 4.7: Piping Materials  
Part 2: Product  
F. Other

1. Fire Hydrants

k. The operating nut shall be .....

&

q. Approved Models:

are hereby revised as follows:

*k. The operating nut shall be tapered, pentagon (five sided) measuring 1½" point to flat (National Standard) at the bottom of the nut, and shall open by turning to the right (clockwise).*

*q. Approved Models:*

- *American Darling B84B*
- *Clow Medallion Hydrant*
- *EJ WaterMaster 5CD250*
- *Mueller Centurion*

*Thomas M. Dahl*

Thomas M. Dahl, P.E., CFM  
City Engineer