



**CITY OF WACO**

**Municipal Information**

Post Office Box 2570  
Waco, Texas 76702-2570  
254 / 750-5636  
Fax: 254 / 750-5634  
www.waco-texas.com

---

**FOR IMMEDIATE RELEASE:**

Contact: Jonathan Echols, PR Coordinator  
Waco Water Utility Services  
(254) 750-8416 jonathane@ci.waco.tx.us

## **Notice of Wastewater Discharge**

Waco, Texas (April 26, 2019) – Due to a break in a wastewater main, an unauthorized discharge of wastewater occurred from the City of Waco Wastewater Collection System.

The discharge, totaling approximately 78,000 gallons of domestic wastewater, occurred near 15000 Hannah Hill Rd, along the Cotton Belt Walking Trail. The discharge was stopped and clean-up activities are underway.

Facility Name: City of Waco Wastewater Collection System

Person to contact for information: Lisa Tyer, (254) 750-8040

Location of spill(s): along the Cotton Belt Walking Trail, near 15000 Hannah Hill Rd.

Estimated date and time of spill(s): April 25, 2:30 p.m.

Estimated volume of spill(s)(number of gallons): 78,000 gallons

Type of Spill (domestic, industrial, other): domestic wastewater

Area potentially affected: area along the Cotton Belt Walking Trail, near 15000 Hannah Hill Rd.

Suspected cause of spill(s): break in a wastewater line

**List of actions taken include, but are not limited to:**

- Notification of appropriate local government officials
- Notification of TCEQ Regional Office
- Clean-up activities are underway / completed.

---

**THIS IS NOT A BOIL WATER NOTICE.** The information below includes mandatory health safety statements required by the Texas Commission on Environmental Quality. The city's wastewater collection system is completely separate from the drinking water system and **the City of Waco has no reason to believe drinking water, distributed by the City of Waco, has been compromised or affected in any way.**

---

**Persons May Wish to Take the Following Personal Precautions:**

- Persons using private drinking water supply wells located within ½ mile of the spill site or within the potentially affected area should use only water that has been distilled or boiled at a rolling boil for at least one minute for all personal uses including drinking, cooking, bathing, and tooth brushing. Individuals with private water wells should have their well water tested and disinfected, if necessary, prior to discontinuing distillation or boiling.
- Persons who purchase water from a public water supply may contact their water supply distributor to determine if the water is safe for personal use.
- The public should avoid contact with waste material, soil, or water in the area potentially affected by the spill.
- If the public comes into contact with waste material, soil, or water potentially affected by the spill, they should bathe and wash clothes thoroughly as soon as possible.

# # #