



CITY OF WACO

Inspection Services

Post Office Box 2570
Waco, Texas 76702-2570
254.750.5612
Permits@wacotx.gov
www.waco-texas.com

Life Safety Inspection Checklist

Short term rental units are subject to inspection prior to issuance of a short term rental operating license. A Life Safety Inspection (LSI) must be approved by the Inspection Services Department prior to issuance of any license for short term rental. This inspection includes, but is not limited to:

- Address numbers must be clearly visible.
- Emergency evacuation plan must be posted in all sleeping rooms.
- Smoke detectors must be operational and installed in all sleeping rooms and immediately outside all sleeping rooms.
- CO2 detectors are required if the house has any gas appliances, or if there is an attached garage on the house.
- Sleeping room windows (or exterior doors) must be operational.
- Water Heaters must have T & P valves and if gas, be vented through the roof.
- No exposed wiring. Remove Extension cords/multi-plug adapters.
- If exterior stairways to a garage apartment or home are present, make sure stairs are stable and in good shape. Code compliant handrails are required.
- All swimming pools must meet the 2015 International Pool & Spa codes. Pool gates, fences (4' fence must go to 6'), and back door alarms must be in place and meet UL 2017 code. (if applicable).
- Applicable City Ordinances, to include zoning, parking, sanitation, signs, STR, and all adopted building and maintenance codes.