



CITY OF WACO

Purchasing Services
Post Office Box 2570
Waco, Texas 76702-2570
254 / 750-8062
Fax: 254 / 750-8063
www.waco-texas.com

Date: **May 23, 2019**
RFP No: **2019-023**
Commodity: **WMARSS Central Plant, Generator Exhaust Quality Improvements**

Mandatory Pre- Proposal Time: 10:00 A.M., May 20, 2019; CT
Closing Time: 2:00 P.M., June 07, 2019; CT
Opening Time: 2:01 P.M., June 07, 2019; CT

Bid Opening Location: Purchasing Services Office, 1415 N. 4th Street, Waco, TX 76704

Addendum No: 1

The above-mentioned proposal invitation has been changed in the following manner. **Sign and return addendum to the Purchasing Office by the closing time and date with your RFB response.** Returning this page signed by your authorized agent will serve to acknowledge this change. All other requirements of the invitation remain unchanged. If you have any questions, please call or stop by the Purchasing Office at the above address.

THE FOLLOWING IS BEING ISSUED AS ADDENDUM NO. 1

- **Answers to Pre-Submittal Meeting Questions on Monday, May 20, 2019**

PLEASE REVIEW THE FOLLOWING PAGES

1. Does the city have a cut sheet (specifications) for the existing generators?
 - a. **Vendors may review the provided testing and vendor data for Generator 1. Generator 2 is a similar model; however, testing data for that unit is unavailable.**
2. How much DEF chemical does the city wish to store?
 - a. **Please provide 30 day chemical storage. You are encouraged to also propose a 90 day storage as an alternate.**
3. Does the city prefer single or double wall chemical storage tanks?
 - a. **Bulk chemical storage must have containment. You may provide a single wall tank within an approved chemical containment facility or you may provide a double wall containment tank on a concrete tank foundation. Be sure to detail tank placement and loading/transfer/feeding/unloading operations within the submitted proposal.**



CITY OF WACO

Purchasing Services
Post Office Box 2570
Waco, Texas 76702-2570
254 / 750-8062
Fax: 254 / 750-8063
www.waco-texas.com

4. Where does the city prefer the catalyst units?
 - a. **The city prefers the unit(s) be inside and accessible for service. However, the City will permit the units to be installed outside if required manufacturer weather protection is provided. The City prefers to not have the units mounted on the roof. Please provide or describe any maintenance access provisions.**
5. May the catalyst units be placed above the generators?
 - a. **Yes, this is a possible solution. Please provide detail including costs, noise level changes, existing equipment modifications, structural amendments or changes, and any other information that should accompany your proposal.**
6. Can the engine radiator units be relocated?
 - a. **Yes, but this cost should be included in your proposal.**
7. Can the existing exhaust piping and pier supported stand outside be removed, replaced, or relocated? Can portions of this equipment be used?
 - a. **Yes and yes. Please describe: any reused equipment, provided/proposed materials, and installation effort(s) in detail. This proposal is for a turn-key effort, please include pricing to perform all necessary tasks.**

Firm: _____

Address _____

Signature of Person
Authorized to Sign Bid: _____

Signor's Name and Title
(Print or type): _____

Date: _____ Telephone: _____ Fax: _____